



Field Trials of PhosFilter Adsorption System For Reduction Of Total Phosphorus (TP) In Residential Stormwater Pond. Numerous Modifications/Adjustments Were Made To The Intake Screen (Algae/Debris Ingestion Issues) Over Several Months. System Fully Operational In Late July 2013. August 27, 2013 Sample Was In Compliance With NNC For First Time In 18 Months. Samples Collected From Pond Outfall To Canal Receiving Water.